

POLLING PLACE AUDIT

POLLING PLACE: MACALPINE WEST PRIMARY, ST LEONARD ROAD

REFERENCE NO 1411

1. ACCESS AUDIT

(a) Car Parking

- | | | |
|----|--|-----|
| 1. | Is parking available nearby and with ample room to open car door (i.e. 3.4m)? | YES |
| 2. | Alternatively, is there a dropping off zone again with ample room to open door? | N/A |
| 3. | Is there a dropped kerb to allow access to main door from parking/dropping off area? | N/A |
| 4. | Are the road/pavement surfaces level and of good quality (e.g. no potholed)? | YES |

(b) Access to Premises

- | | | |
|----|--|-------|
| 1. | Is the access on the flat? | NO |
| 2. | <u>Are there any steps to main door (if yes - how many)?</u> | YES 4 |
| 3. | If there are any steps, is there a handrail? | NO |
| 4. | Is there a ramp? (Gradient 1:) | NO |
| 5. | Are the doors easy to open? | YES |
| 6. | Are the doors at least 800 mm wide? | YES |

(c) Internal

- | | | |
|----|---|------|
| 1. | How far is the polling station from the entrance? | 10 m |
| 2. | If there are corridors/lobbies, are they at least 800mm wide? | YES |
| 3. | Are there any internal stairs to polling station? | NO |
| 4. | Is there a chair (with arms) available? | YES |
| 5. | Are floor surfaces non-slip? | YES |
| 6. | Is lighting sufficient (non-glare)? | YES |

2. COMMENTS BY RETURNING OFFICER

ACCESS IS VIA A TEMPORARY RAMP FROM PLAYGROUND TO GYM HALL.
PARKING IS IN THE PLAYGROUND SO NO DROPPED KERB REQUIRED.

POLLING PLACE AUDIT**POLLING PLACE: ARDLER COMPLEX, TURNBERRY AVENUE****REFERENCE NO 70****1. ACCESS AUDIT****(a) Car Parking**

- | | | |
|----|--|-----|
| 1. | Is parking available nearby and with ample room to open car door (i.e. 3.4m)? | YES |
| 2. | Alternatively, is there a dropping off zone again with ample room to open door? | N/A |
| 3. | Is there a dropped kerb to allow access to main door from parking/dropping off area? | YES |
| 4. | Are the road/pavement surfaces level and of good quality (e.g. no potholed)? | YES |

(b) Access to Premises

- | | | |
|----|--|-----|
| 1. | Is the access on the flat? | YES |
| 2. | <u>Are there any steps to main door (if yes - how many)?</u> | NO |
| 3. | If there are any steps, is there a handrail? | N/A |
| 4. | Is there a ramp? (Gradient 1:) | NO |
| 5. | Are the doors easy to open? | YES |
| 6. | Are the doors at least 800 mm wide? | YES |

(c) Internal

- | | | |
|----|---|------|
| 1. | How far is the polling station from the entrance? | 20 m |
| 2. | If there are corridors/lobbies, are they at least 800mm wide? | YES |
| 3. | Are there any internal stairs to polling station? | NO |
| 4. | Is there a chair (with arms) available? | YES |
| 5. | Are floor surfaces non-slip? | YES |
| 6. | Is lighting sufficient (non-glare)? | YES |

2. COMMENTS BY RETURNING OFFICER

THERE IS PERMANENT RAMPED ACCESS FROM MAIN DOOR TO THE POLLING STATION WHICH IS IN THE MAIN HALL. INTERNAL DOORS ARE WEDGED.

POLLING PLACE AUDIT**POLLING PLACE: ST MARGARET'S PRIMARY, LAUDERDALE AVENUE****REFERENCE NO 75****1. ACCESS AUDIT****(a) Car Parking**

- | | | |
|----|--|-----|
| 1. | Is parking available nearby and with ample room to open car door (i.e. 3.4m)? | YES |
| 2. | Alternatively, is there a dropping off zone again with ample room to open door? | N/A |
| 3. | Is there a dropped kerb to allow access to main door from parking/dropping off area? | NO |
| 4. | Are the road/pavement surfaces level and of good quality (e.g. no potholed)? | YES |

(b) Access to Premises

- | | | |
|----|--|-------|
| 1. | Is the access on the flat? | NO |
| 2. | <u>Are there any steps to main door (if yes - how many)?</u> | YES 3 |
| 3. | If there are any steps, is there a handrail? | YES |
| 4. | Is there a ramp? (Gradient 1:) | NO |
| 5. | Are the doors easy to open? | YES |
| 6. | Are the doors at least 800 mm wide? | YES |

(c) Internal

- | | | |
|----|---|------|
| 1. | How far is the polling station from the entrance? | 30 m |
| 2. | If there are corridors/lobbies, are they at least 800mm wide? | YES |
| 3. | Are there any internal stairs to polling station? | NO |
| 4. | Is there a chair (with arms) available? | YES |
| 5. | Are floor surfaces non-slip? | YES |
| 6. | Is lighting sufficient (non-glare)? | YES |

2. COMMENTS BY RETURNING OFFICER

TEMPORARY RAMPING IS PROVIDED BY THE SCHOOL TO GAIN ACCESS TO THE HALL WHERE VOTING TAKES PLACE. VEHICULAR ACCESS IS ALLOWED TO THE PLAYGROUND SO NO DROPPED KERB IS REQUIRED. SCHOOL IS MERGING WITH ST COLUMBAS ON ST LEONARD PLACE IN 2008.

POLLING PLACE AUDIT**POLLING PLACE: STRATHMARTINE CHURCH HALL, STRATHMARTINE ROAD****REFERENCE NO 74****1. ACCESS AUDIT****(a) Car Parking**

- | | | |
|----|--|-----|
| 1. | Is parking available nearby and with ample room to open car door (i.e. 3.4m)? | NO |
| 2. | Alternatively, is there a dropping off zone again with ample room to open door? | YES |
| 3. | Is there a dropped kerb to allow access to main door from parking/dropping off area? | YES |
| 4. | Are the road/pavement surfaces level and of good quality (e.g. no potholed)? | YES |

(b) Access to Premises

- | | | |
|----|--|-----|
| 1. | Is the access on the flat? | YES |
| 2. | <u>Are there any steps to main door (if yes - how many)?</u> | 4 |
| 3. | If there are any steps, is there a handrail? | N/A |
| 4. | Is there a ramp? (Gradient 1: 11) | YES |
| 5. | Are the doors easy to open? | YES |
| 6. | Are the doors at least 800 mm wide? | YES |

(c) Internal

- | | | |
|----|---|-----|
| 1. | How far is the polling station from the entrance? | 5 M |
| 2. | If there are corridors/lobbies, are they at least 800mm wide? | YES |
| 3. | Are there any internal stairs to polling station? | NO |
| 4. | Is there a chair (with arms) available? | YES |
| 5. | Are floor surfaces non-slip? | YES |
| 6. | Is lighting sufficient (non-glare)? | YES |

2. COMMENTS BY RETURNING OFFICER

VOTING IS IN THE BIG HALL. THERE ARE 2 ENTRANCES TO THE BUILDING. STRATHMARTINE ROAD HAS 2 STEPS. HARESTANE PLACE IS DIRECT FROM THE STREET. PATHWAYS LEAD TO THE HALL WHICH HAS RAMPED ACCESS.

POLLING PLACE AUDIT**POLLING PLACE: BALDRAGON ACADEMY, BURN STREET****REFERENCE NO 76****1. ACCESS AUDIT****(a) Car Parking**

- | | | |
|----|--|-----|
| 1. | Is parking available nearby and with ample room to open car door (i.e. 3.4m)? | YES |
| 2. | Alternatively, is there a dropping off zone again with ample room to open door? | N/A |
| 3. | Is there a dropped kerb to allow access to main door from parking/dropping off area? | NO |
| 4. | Are the road/pavement surfaces level and of good quality (e.g. no potholed)? | YES |

(b) Access to Premises

- | | | |
|----|--|-----|
| 1. | Is the access on the flat? | YES |
| 2. | <u>Are there any steps to main door (if yes - how many)?</u> | NO |
| 3. | If there are any steps, is there a handrail? | N/A |
| 4. | Is there a ramp? (Gradient 1:) | NO |
| 5. | Are the doors easy to open? | YES |
| 6. | Are the doors at least 800 mm wide? | YES |

(c) Internal

- | | | |
|----|---|------|
| 1. | How far is the polling station from the entrance? | 15 m |
| 2. | If there are corridors/lobbies, are they at least 800mm wide? | YES |
| 3. | Are there any internal stairs to polling station? | NO |
| 4. | Is there a chair (with arms) available? | YES |
| 5. | Are floor surfaces non-slip? | YES |
| 6. | Is lighting sufficient (non-glare)? | YES |

2. COMMENTS BY RETURNING OFFICER

VOTING TAKES PLACE IN THE LIBRARY. THERE ARE TWO DISABLED SPACES IN CAR PARK IMMEDIATELY IN FRONT OF THE MAIN ENTRANCE.

POLLING PLACE AUDIT**POLLING PLACE: SIDLAWVIEW PRIMARY, HARESTANE ROAD****REFERENCE NO 77****1. ACCESS AUDIT****(a) Car Parking**

- | | | |
|----|--|-----|
| 1. | Is parking available nearby and with ample room to open car door (i.e. 3.4m)? | YES |
| 2. | Alternatively, is there a dropping off zone again with ample room to open door? | N/A |
| 3. | Is there a dropped kerb to allow access to main door from parking/dropping off area? | YES |
| 4. | Are the road/pavement surfaces level and of good quality (e.g. no potholed)? | YES |

(b) Access to Premises

- | | | |
|----|--|-------|
| 1. | Is the access on the flat? | NO |
| 2. | <u>Are there any steps to main door (if yes - how many)?</u> | YES 2 |
| 3. | If there are any steps, is there a handrail? | YES |
| 4. | Is there a ramp? (Gradient 1: 15) | YES |
| 5. | Are the doors easy to open? | YES |
| 6. | Are the doors at least 800 mm wide? | YES |

(c) Internal

- | | | |
|----|---|------|
| 1. | How far is the polling station from the entrance? | 10 m |
| 2. | If there are corridors/lobbies, are they at least 800mm wide? | YES |
| 3. | Are there any internal stairs to polling station? | NO |
| 4. | Is there a chair (with arms) available? | YES |
| 5. | Are floor surfaces non-slip? | YES |
| 6. | Is lighting sufficient (non-glare)? | YES |

2. COMMENTS BY RETURNING OFFICER

VEHICULAR ACCESS TO PLAYGROUND OFF HARESTANE ROAD. 1 DISABLED SPACE. PERMANENT RAMPED ACCESS (1:15) DIRECT TO MAIN HALL WHERE VOTING TAKES PLACE. ALSO PERMANENT RAMPED ACCESS FOR ALL VOTERS AT MAIN ENTRANCE - OFF HELMSDALE PLACE.

POLLING PLACE AUDIT**POLLING PLACE: KIRKTON NEIGHBOURHOOD CENTRE, DERWENT AVENUE****REFERENCE NO 77****1. ACCESS AUDIT****(a) Car Parking**

- | | | |
|----|--|-----|
| 1. | Is parking available nearby and with ample room to open car door (i.e. 3.4m)? | YES |
| 2. | Alternatively, is there a dropping off zone again with ample room to open door? | N/A |
| 3. | Is there a dropped kerb to allow access to main door from parking/dropping off area? | YES |
| 4. | Are the road/pavement surfaces level and of good quality (e.g. no potholed)? | YES |

(b) Access to Premises

- | | | |
|----|--|-------|
| 1. | Is the access on the flat? | YES |
| 2. | <u>Are there any steps to main door (if yes - how many)?</u> | YES 3 |
| 3. | If there are any steps, is there a handrail? | YES |
| 4. | Is there a ramp? (Gradient 1: 10) | YES |
| 5. | Are the doors easy to open? | YES |
| 6. | Are the doors at least 800 mm wide? | YES |
- (c) Internal**
- | | | |
|----|---|------|
| 1. | How far is the polling station from the entrance? | 10 m |
| 2. | If there are corridors/lobbies, are they at least 800mm wide? | YES |
| 3. | Are there any internal stairs to polling station? | NO |
| 4. | Is there a chair (with arms) available? | YES |
| 5. | Are floor surfaces non-slip? | YES |
| 6. | Is lighting sufficient (non-glare)? | YES |

2. COMMENTS BY RETURNING OFFICER

VOTING IS IN ENTERTAINMENT ROOM. 2 DISABLED SPACES IN CAR PARK - 20M FROM MAIN ENTRANCE.

POLLING PLACE AUDIT**POLLING PLACE: DOWNFIELD PRIMARY, SCHOOL ROAD****REFERENCE NO 71****1. ACCESS AUDIT****(a) Car Parking**

- | | | |
|----|--|-----|
| 1. | Is parking available nearby and with ample room to open car door (i.e. 3.4m)? | YES |
| 2. | Alternatively, is there a dropping off zone again with ample room to open door? | N/A |
| 3. | Is there a dropped kerb to allow access to main door from parking/dropping off area? | YES |
| 4. | Are the road/pavement surfaces level and of good quality (e.g. no potholed)? | YES |

(b) Access to Premises

- | | | |
|----|--|-----|
| 1. | Is the access on the flat? | YES |
| 2. | <u>Are there any steps to main door (if yes - how many)?</u> | NO |
| 3. | If there are any steps, is there a handrail? | N/A |
| 4. | Is there a ramp? (Gradient 1:) | YES |
| 5. | Are the doors easy to open? | YES |
| 6. | Are the doors at least 800 mm wide? | YES |
- (c) Internal**
- | | | |
|----|---|------|
| 1. | How far is the polling station from the entrance? | 25 m |
| 2. | If there are corridors/lobbies, are they at least 800mm wide? | YES |
| 3. | Are there any internal stairs to polling station? | NO |
| 4. | Is there a chair (with arms) available? | YES |
| 5. | Are floor surfaces non-slip? | YES |
| 6. | Is lighting sufficient (non-glare)? | YES |

2. COMMENTS BY RETURNING OFFICER

VOTING IS IN GYM HALL. INTERNAL DOORS WEDGED. PARKING IN BANK AVENUE. DROPPED KERB ACCESS FROM HERE. NO PARKING ON EAST SCHOOL ROAD. SCHOOL RELOCATING TO NEW BUILD ON SITE AT HALDANE CRESCENT 2008.